SRI SRINIVASA BOREWELLS AND PUMPS

8th Cross Rd, near Kadaenahalli, RK Layout, Padmanabhanagar, Bengaluru, Karnataka 560070,

Dated 18/03/2022

No.

WORK TECHNICAL REPORT

To,

Assistant Executive Engineer, Yelahanka Satellite
Town Sub Division, Yelahanka Division,
BBMP Bangalore,

Location : At 9th A Cross, A Sector, Near NES Bus Stop

Sl No	Particular	Rft	Water Yeild	Remarks
1	Size of the Borewell	6 ½ Inches		
2	Total Depth of the Borewell	1150 00		
3	MS Casing Erected	165 00		
4	1st Water Source at the Depth	750 00		
5	2nd Water Source at the Depth	900 00		
6	3rd Water Source at the Depth	1155 00		
7	4th Water Source at the Depth	-		
8	If any Silt Boulders at the Depth	-		
9	Nature of Water	Good		
10	Motor Pump to be used	Yes		
11	Any Other Remarks			
12	Total Yield of the Borewell	2400 G/h		

Your faithfully

Nagaraju

(B.N. Nagaraju)

SRI SRINIVASA BOREWELLS AND PUMPS

8th Cross Rd, near Kadaenahalli, RK Layout, Padmanabhanagar, Bengaluru, Karnataka 560070,

Dated -18/03/2022

No.

WORK TECHNICAL REPORT

To,

Assistant Executive Engineer, Yelahanka Satellite town Sub division, Yelahanka Division, BBMP Bangalore

Location : At Cauvery Park, Yelahanka Upanagara

Sl No	Particular	Rft	Water Yeild	Remarks
1	Size of the Borewell	6 ¼ Inches		
2	Total Depth of the Borewell	1150.00		
3	MS Casing Erected	168.00		
4	1st Water Source at the Depth	650.00		
5	2nd Water Source at the Depth	900.00		
6	3rd Water Source at the Depth	1150.00		
7	4th Water Source at the Depth	-		
8	If any Silt Boulders at the Depth	-		
9	Nature of Water	Good		
10	Motor Pump to be used	Yes		
11	Any Other Remarks			
12	Total Yield of the Borewell	2300 G/h		

Your faithfully

Nagaraju

(B N. Nagaraju)